



Certificate of Compliance

Certificate: 2292067 (218481)

Master Contract: 218481

Project: 70040990

Date Issued: 2015-09-08

Issued to: Max-Air Technology, Inc.
751 Hoff Rd
O'Fallon, Missouri 63366
USA

Attention: Jeffrey Ellebrecht

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Rajinder Jakhu
Rajinder Jakhu

PRODUCTS

CLASS - C322181 - VALVES-Certified to US Standards
CLASS - C322801 - VALVES-For Hazardous Locations

Electrically Operated Solenoid Valves, SV61 Series and SV21 Series rated 12VDC, 24VDC, 125VDC, 24VAC, 48VAC, 120VAC and 220VAC, 50/60 Hz, 7W; Max. Operating Pressure – 120psi; Coil Insulation Class: F or H.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 139-13 - Electrically operated valves - Fourth Edition
UL 429:2013 - Electrically Operated Valves - Seventh Edition



Supplement to Certificate of Compliance

Certificate: 2292067 (218481)

Master Contract: 218481

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70040990	2015-09-08	Alternate coil
2703749	2014-05-02	Add model SV21
2589399	2013-05-22	Report Update to comply with C22.2 No. 139-10 (Notice 8)
2292067	2010-08-19	Solenoid Valves, SV61 series rated 12VDC, 24VDC, 24VAC, 120VAC AND 220VAC.