



Certificate of Compliance

Certificate: 2603565 (218481)

Master Contract: 218481

Project: 70028048

Date Issued: April 08, 2015

Issued to: Max-Air Technology, Inc.
751 Hoff Rd
O'Fallon, Missouri 63366
USA
Attention: Jon Davis

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: William Kinas
William Kinas

PRODUCTS

CLASS - C321107 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus

CLASS - C321187 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus - Certified to US Standards

Limit Switch Boxes with Type 4X Enclosures:

Model Series Max Ratings @ 60Hz, 1 phase

MS45	5A @ 125Vac	3A @ 250Vac	3A @ 30Vdc
PS45	0.25A @ 120Vac	0.25A @ 175Vdc	
IS45	0.2A @ 20-140Vac	0.2A @ 10-140Vdc	
BE45	5A @ 125Vac	3A @ 250Vac	3A @ 30Vdc
BM45	0.25A @ 120Vac	0.25A @ 175Vdc	
BS45	0.2A @ 20-140Vac	0.2A @ 10-140Vdc	

Note: The model series above may have a suffix of letter and/or number designators representing various options as detailed in the descriptive report. Models may have a "Q" prefix indicating private labeling for QSM Inc.

APPLICABLE REQUIREMENTS

CSA C22.2 No 14-13 - Industrial Control Equipment
ANSI/UL 508 (17th Ed) - Industrial Control Equipment



Certificate: 2603565
Project: 70028048

Master Contract: 218481
Date Issued: April 08, 2015

CSA C22.2 No 94.1-07 / ANSI/UL 50 (12th Ed) - Enclosures for Electrical Equipment, Non-Environmental Considerations
CSA C22.2 No 94.2-07 / ANSI/UL 50E (1st Ed) - Enclosures for Electrical Equipment, Environmental Considerations



Supplement to Certificate of Compliance

Certificate: 2603565 (218481)

Master Contract: 218481

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
70028048	Apr 8 2015	Update report to add electrical ratings to model series and update part number code system used in the model number nomenclature.
70012282	Feb 17 2015	Update report to add alternate switches, update model nomenclature, and add alternate pcb layouts. Updated the report to C22.2 No. 14-13 per Informa Industrial Control Equipment No. 36.
2603565	Jun 11 2013	Original certification of Limit Switch Boxes Model Series: MS45-2XX, PS45-2XX, IS45-2XX, BE45-2XX, BS45-2XX, and BM45-2XX, with type 4X enclosures.